

**CRESTED BUTTE FIRE PROTECTION DISTRICT**

306 MAROON AVENUE
P.O. BOX 1009
CRESTED BUTTE, COLORADO 81224
(970) 349-5333

COPY

9/29/08

Frank Glick
Mt Crested Butte Water & Sanitation District
PO Box 5740
Mt Crested Butte, CO 81225

Letter # 2008-2-074

RE: Fire flows for Meridian Lake Park Corporation

Dear Frank,


On 9/16/08 & 9/17/08 the Fire Division of the Crested Butte Fire Protection District in conjunction with the Mt CB Water & Sanitation District performed fire flow tests for the Meridian Lake Park water distribution system. The result of these tests indicated that there has not been any significant improvement in the capacity or ability of the water distribution system to provide the required fire flows. Attached is the spreadsheet from 5/20/03 indicating the fire flows from that date and the fire flows from our tests on 9/16 & 9/17/08 based on one 2.5 inch opening. The results are basically the same.


As you are aware, the required fire flows is 1750gpm for duration of 2 hours per the attached correspondence from the Homeowners Association dated 2/21/07, 3/1/07 and CBFPD letter # 2007-2-027 dated 2/26/07 regarding required fire flows.

We look forward to reviewing plans for the system upgrade per previous correspondence.

If you have any questions or need further clarification, please contact our offices.

Respectfully,


Scott Wimmer
Fire Inspector
Crested Butte Fire Protection District


Ric Ems
Fire Chief / Fire Marshal
Crested Butte Fire Protection District

Cc: Bill Ronai, President, Meridian Lake Meadows Corporation

Attachments: Spreadsheet of Fire Flows dated 5/20/03
Fire Flows on 9/16-17/08
MLP Corporation correspondence dated 2/21/07 & 3/1/07
CBFPD letter # 2007-2-027 dated 2/26/07

